



Certificate number: 2303712 (1)

Issued 13/03/2023

Expires 13/03/2028

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Aquacheck Engineering Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Aquacheck Engineering Ltd
Royle Barn Road
Castleton
Rochdale
OL11 3DT
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2303712

The following products belong to this certificate

PRODUCT DESCRIPTION 'Aquacheck' range of spring-loaded resilient trim, non-return valves with blue epoxy coated ductile iron bodies, stainless steel springs and EPDM seals. ATS3 – Without Production Surveillance.
MODEL(S) Aquacheck.
SIZE: DN50, 65, 80, 100, 125, 150.
SCOPE: Manufacturer recommended maximum working pressure 16 Bar & maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only. Above ground use only.
MARKING Aquacheck, size, flow arrow and pressure rating on body.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES Not suitable for backflow protection.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes